

4240 Passmore Upper Road, Winlaw BC, V0G 2J0
 250-226-7339
 test@passmorelaboratory.ca
 passmorelaboratory.ca

Attention	Dominique	Project
Client	Slocan River Streamkeepers	Project Info

CERTIFICATE OF ANALYSIS

<u>Analyses</u>	<u>Method Description</u>	<u>Reference</u>
Total Coliforms	Membrane Filtration on LES Endo medium	APHA 9222B
E. coli	MF Partition on NA-MUG medium	APHA 9222I
Fecal Coliforms	Membrane Filtration on mFC medium	APHA 9222D

Tests were performed in accordance with methods outlined in the "Standard Methods for the Examination of Water and Wastewater", 23rd Edition, 2017 published by the American Public Health Association.

Passmore Laboratory Ltd. complies with methods and certification through the Province of British Columbia Enhanced Water Quality Assurance (EWQA) Program and the Clinical Microbiology Proficiency Testing (CMPT) Program. Other analytical results on this report not listed above are not within the scope of the EWQA.

Processed by: Lynne Alexander

Jennifer Yeow,
 Lab Manager



Please call or Email for with any questions, feedback, or more information

ANALYTICAL RESULTS

Sample ID	Winlaw Creek		Sample # 1
Sample Date/Time	8/23/2021	4:00 PM	Source: Creek

Date/Time on test 8/23/2021 5:00 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
Coliforms, Total	19	CFU/100mL	1
Verified E.coli	Positive*	CFU/100mL	1
Fecal (Thermotolerant) Coliforms	12	CFU/100mL	1

Comments *Unable to count due to excessive sediment. The sample does not meet drinking water guidelines

Sample ID	Trozzo Creek		Sample # 2
Sample Date/Time	8/23/2021	10:00 AM	Source: Creek

Date/Time on test 8/23/2021 5:05 PM

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
Coliforms, Total	>50	CFU/100mL	1
Verified E.coli	11	CFU/100mL	1
Fecal (Thermotolerant) Coliforms	11	CFU/100mL	1

Comments The sample does not meet drinking water guidelines

Sample ID	Sample # 3
-----------	------------

<u>Analyses</u>	<u>Result</u>	<u>Units</u>	<u>RDL</u>
-----------------	---------------	--------------	------------

Glossary of Terms

Less than 1	Less than the Reportable Detection Limit, except under circumstances where the detection limit is higher due to interferences, insufficient sample volume, or dilutions.
APHA	American Public Health Association
CFU/100mL	Colony Forming Units per 100 milliliters
MAC	Maximum Acceptable Concentration
Matrix	SW = Surface water, TW =Treated water, DW= Distribution water, UGW = Untreated Ground water, RW = Raw water
RDL	Reportable Detection Limit

References